

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/ 479

Dated: 31/08/2023

To

The Joint Commissioner of Police,
Lic, Unit 1st Floor, Police Station,
Defence Colony, New Delhi 110049.

Sub: Regarding issue of Fire Safety Certificate in r/o M/s DANZA TERRAZA (Unit of Out putt Project India Pvt Limited) at Plot No 1, at Paras Cinema District Centre Nehru Place, Kalkaji, New Delhi-110019

Sir,

This is in reference to your **MHA Portal ID 2023080113741** dated **03/08/2023** on the subject cited above. In this concerned it is to inform you that the premise was inspected by the concern nominated authority of this department in presence of Mr. GS Rawat (Manger) on dated 21/08/2023 to ascertain the availability and operability of fire protection and fire safety measure. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are 04 Nos of Staircase available in the Mall, out of 04 staircases, 01 staircase has been compromised by the restaurant.
2. There are two exit having width of 1.50 mtr & 1.20 mtr against the required width of 1.50 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/ur