

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2023/SZ/ 1880
To

Dated: 02/09/2023

Mr. Mukesh Sharma (Dy. GM / Engg.),
International Craft complex
Plot No 08, Shopping Mall Area,
Nelson Mandela Marg, Vasant Kunj, New Delhi

Sub: Regarding issuance of FSC in r/o M/s International Craft complex Plot No 08, Shopping Mall Area, Nelson Mandela Marg, Vasant Kunj, New Delhi

Sir,
This has reference to your letter no NBCC/DGM/Vasant Kunj/22023/422 dated 19/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29.08.2023 in the presence of Mr. Siddharth to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Staircase is not properly segregated at ground floor as per clause 7.11 (t) of UBBL 2016.
2. The Pressurization of staircase not provided.
3. The exit doors width is 1.30 mtr against the required width of 1.50 mtr.
4. Ventilation system not provided.
5. Automatic fire detection & alarming system not provided.
6. The MOEFA system not provided.
7. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]