

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2023/EH/ 481

Dated 31/08/2023

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Kanwar Saini Anil Kumar (Eating House) located at Shop No-5202, New Chandrawal Road, Sabzi Mandi, Ghanta Ghar, Delhi-110007.

Sir,

This has reference to online mha portal I'd. No. 2023081614641 dated 17.08.2023 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officer concerned of this department on 24.08.2023 in the presence of Mr. Ayush Gupta to verify the fire safety measures not installed in the building and observed that the building is comprised of ground & 02 upper floors but restaurant is running at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Smoke ventilation systems not provided.
2. Hose reel hose not provided.
3. MOEFA System not provided.
4. Internal hydrants not provided.
5. Terrace level fire pump capacity of 450 lpm not provided.
6. Overhead water storage tank capacity of 20,000ltrs for firefighting purpose not provided.
7. Exit signage not provided in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of eating house is at your own risk & responsibility.

Yours faithfully,


(Anil Garg)
Director

Ph: 011-23414000

Copy to:-

1. Kanwar Saini Anil Kumar (Eating House) located at Shop No-5202, New Chandrawal Road, Sabzi Mandi, Ghanta Ghar, Delhi-110007