

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2021/EH/NDZ/ 73

Dated: 45.162.12021

To,

The Dy. Commissioner of Police (Lic.) First floor, PS Defence Colony, New Delhi

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Biryani Blues (A Unit of Thea Kitchen Pvt Ltd), Showroom No.9, Atma Ram Mansion, Scindia House, New Delhi.

Sir.

This has reference to on line ID No. 2020111708510 dated 29.12.2020, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 13/01/2021 in the presence of Sh. Devesh Kumar and following shortcomings were observed:-

- 1. Width of staircases provided 1.0 & 1.20 mtr against the requirements of 1.5 meter.
- 2. Exit door width provided 1.20m & .65m against the requirements of 2.0 & 1.5 meter. Further, alternate exit shall not be accessed through kitchen.
- 3. First aid hose reel is not provided.
- 4. MOEFA is not provided.
- 5. Internal hydrant is not provided.
- 6. Terrace pump is not provided.
- 7. Overhead tank of capacity 20,000 liter is not provided.
- 8. Exit signages found inadequate.

9. Stand by power supply is not provided.

Further, details mentioned in application form such as height of the building, number of specific floor on which establishment is established, width of staircase & no. of staircases are not matching with the parameter of the building existing on site. Moreover, the as built plan duly signed by the Emplaned engineer/Registered architect & Owner/Occupier and area details of the establishment is also not uploaded on the site

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to direct the applicant to rectify the above

shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

Copy to :-

1. The Manager, M/S Biryani Blues (A Unit of Thea Kitchen Pvt Ltd), Showroom No.9, Atma Ram Mansion, Scindia House, New Delhi.