

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/ 487
To

Dated 04/09/2023

The Dy. Health Officer, MCD,
Public Health Officer,
Aurobindo Marg, Green Park,
New Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Dirty Rabbit (A Unit of Time House Restaurant Pvt Ltd) located at HS-9, Second Floor & Third Floor, Kailash Colony Market, New Delhi 110048.

Sir,

This has reference to with MHA Portal ID2023081514607 dated 16/08/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.08.2023 in the presence of Mr. Pathak (Care taker) to verify the fire safety measures installed in the building and observed that restaurant running at 2nd & 3rd Floor only. During inspection, following points were observed:

- 1 MOEFA not provided.
- 2 Electric Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
- 3 Underground water storage tank for fire fighting having capacity 1, 00,000 ltrs not provided.
- 4 Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Joint Commissioner of Police (Lic/Branch) 1st Floor PS Defence Colony, New Delhi 110049 (Ref. MHA Portal ID2023081514607 dated 16/08/2023)