

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/SZ/ 484

Dated 04/09/2023

To

The Dy. Health Officer, MCD,  
Public Health Officer,  
Aurobindo Marg, Green Park Zone,  
Green Park, Delhi 110016

**Sub: -** Regarding issuance of fire safety certificate in r/o M/s Foodies ET AL India Pvt Ltd located at C-32/B, Nathu Singh Market, Masoodpur Vasant Kunj, New Delhi 110070.

Sir,

This has reference to with MHA Portal ID. 2023081014374 dated 18/08/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.08.2023 in the presence of Md. Noor to verify the fire safety measures installed in the building and observed that restaurant running at Ground floor only. During inspection, following points were observed:

- 1 The Fire tender/fire engine is not accessible due to the premise.
- 2 There is one exit door having width of 1 mtr against the required two doors having width of 1.50 mtr each.
- 3 First Aid Hose reel hose not provided.
- 4 MOEFA not provided.
- 5 Internal Hydrants not provided.
- 6 Terrace level Fire Pump capacity of 450 LPM not provided.
- 7 Overhead tank capacity 20,000 ltrs not provided.
- 8 Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

*[Handwritten signature]*