



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2023/SZ/ 1896
To

Dated: 05.10.2023

The Executive Engineer (E)
Electrical Division No 1/DDA,
M/s Utsav Sthal Pandal,
Madangir Near Virat Cinema, New Delhi

Sub: Regarding issuance of FSC in r/o M/s Utsav Sthal Pandal at Madangir Near Virat Cinema, New Delhi

Sir,

This has reference to your letter no F3 (194)EE/(E)/ELD-11/DDA/2023-24/216 dated 10/08/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.08.2023 in the presence of Mr. Kushal Khurana (Project) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel not provided.
2. MOEFA provided but found not functional.
3. Automatic sprinkler system not provided
4. Internal and yard hydrant not provided.
5. Terrace level fire fighting pumps capacity 900 LPM provided but found not functional.
6. Overhead tank capacity 25,000 ltrs not provided.
7. Exit Signage not provided.
8. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

