



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/WZ/2023/1915

Dated: 06/09/2023

To,

Sh. Ajay Bindal (Authorized Signatory),
M/s. Aggarwal Prestige Mall,
Plot No. 02, Community Centre,
Adjoining Road No. 44, Pitampura,
(Rani Bagh), New Delhi.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s. Aggarwal Prestige Mall located at Plot No. 02, Community Centre, Adjoining Road No. 44, Pitampura (Ranibagh), New Delhi.

Sir,

Please refer to your letter No. USHPL/AS/APM/DFS/2K23/360 dated 16/05/2023, received through outdoor diary no. 4564 dated: - 07/08/2023, on the subject cited above. In this connection, it is to inform you that the premises was re - inspected by officer concerned of this department on 29/08/2023 in the presence of Sh. Ajay Bindal check the shortcomings already issued by this department vide letter no. F.6/DFS/MS/WZ/2023/1400 dated 07/07/2023.

The Status of the Shortcoming is as under:-

S. no.	Shortcomings	Status
1.	Detection system found removed at some places.	Rectified
2.	Pressurization in lift lobby found removed.	Not Rectified
3.	Door closer of fire check doors found broken/non-functional.	Not Rectified
4.	Exit signages found removed.	Rectified

In addition to above following short coming were observed

1. Fire check doors are found removed at some places.

In view of above, application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Ajay Garg)
Director

s/c
04/9/2023