

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/MS/DFS/Hospital/2023/SZ/ 19/7

Dated 06/09/2023

To

The Ex-Engineer (Pr.) -II, (South Zone)  
Municipal Corporation of Delhi  
Under Sewa Nagar Flyover New Delhi

**Sub:** -Regarding issuance of Fire Safety Certificate in r/o M & CW Centre Polyclinic at Fatehpur Beri Delhi

Sir,

This has reference with letter no D/EE (Pr)-II SZ/2023-24/119 dated 31/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31.08.2023 in the presence of Mr. Gaurav JE/Elect. to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 Sealing of Electrical Shaft not sealed.
- 2 First aid hose reel provided but found not functional and nozzles are missing.
- 3 Automatic detection system not provided.
- 4 MOEFA not provided
- 5 Automatic sprinkler system provided found non functional.
- 6 Internal hydrant and yard hydrant non functional.
- 7 Fire fighting pumps are not functional.
- 8 Exit Signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

o/w n