

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Hospital/2023/SZ/ 1929

Dated: 06.10.2023

To

M/s Cloudnine Hospital,
(Kids Clinic India Ltd)
Plot No A-18, Kailash Colony,
New Delhi 110048.

Sub: Regarding issuance of FSC in r/o M/s Cloudnine Hospital, (Kids Clinic India Ltd) at Plot No A-18, Kailash Colony, New Delhi 110048.

Sir,

This has reference to your letter received through outdoor diary no 2845 dated 15/06/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31.08.2023 in the presence of Mr. Radish (Technician) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Exit door width at one staircase (out of two staircases) is 1.20 mtr, against the required of 1.50 mtr.
2. Sealing of electrical / plumbing shaft are not sealed for proper Compartmentation/ segregation as per UBBL 2016.
3. The ventilation system is not provided for clause 8.4.5 as per UBBL / NBC.
4. Sprinkler system could not be checked due to non availability of sprinkler testing value.
5. The work relates to erection of second staircase in basement is in progress.
6. There are deviations in either building the plan of vis to vis building plans approved by the department. Hence, the management is here by advised, to refer two sets of re-revised building plans (current occupancy) including section/elevation/lay out plan on the scales as mentioned in UBBL 2016 duly marked with fire and life safety systems as per NBC part 4. (Through common application form (CAF))

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Dr. Nitin Kumar, Medical Superintendent Nursing Homes, Directorate General of Health Services, 3rd Floor, DGD Building, S-1, School, Block, Shakarpur, New Delhi 110092