



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

75
 आजादी का
 अमृत महोत्सव

No. F6/DFS/MS/WZ/College/2023/ 68

Dated: 06/09/2023

To,

The Authorized Signatory,
 Frankfinn Aviation Services Pvt. Ltd.,
 A-16, Vishal Enclave, Near Oriental Bank,
 New Delhi: - 110027.

Subject: - **Regarding renewal of Fire Safety Certificate in r/o Frankfinn Aviation Services Pvt. Ltd. Located at A-16, Vishal Enclave, Near Oriental Bank, New Delhi: - 110027.**

Sir,

This is in reference to your letter no. nil dated nil, received through outdoor diary no. 4718 dated: 09/08/2023 on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 25/08/2023 in the presence of Sh. Rahul Kamboj (Manager) to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/2023/WZ/College/32 dated: 06/07/2023. However, the status of shortcomings is as under.

S. No.	Shortcomings	Status
1.	The width of Corridor at 3 rd floor found reduced to 1.0m against required of 1.5m.	Not Rectified
2.	First aid hose reel found non-functional & 2 nd floor hose reel drum found removed.	Rectified
3.	Fire Pump of 450 lpm capacity found non – functional.	Rectified but not on auto mode
4.	Overhead water storage tank found domestic connection. Overhead water storage tank are delicately metered for fire fighting.	Not Rectified
5.	Standby power supply found removed.	Rectified
6.	Exit signages found removed.	Rectified
7.	Smoke management system is not provided in upper floor.	Not Rectified
8.	Lift grounding switch found non-functional.	Rectified

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/Premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/Occupier. You are advised to rectify the above the above mentioned shortcoming & submit point-wise compliance to this department.

Yours faithfully,

(Atul Garg)
 Director

dc/PP-1
 31/8/2023