

c/190

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 11/09/2023

No. F6/DFS/MS/School/2023/SZ/ 390

To,

The Manager,
Holy Innocents Public School,
Plot No.-PS/09, C-Block, Vikaspuri,
New Delhi-110018.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Holy Innocents Public School, Plot No.-PS/09, C-Block, Vikaspuri, New Delhi-110018.

Sir,

Please refer to your letter No. HIPS/FS/MS/2023 dated 18/08/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 24/08/2023 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Neeraj Kumar (Account) was present and it was observed that the building is comprised of basement, ground floor plus three upper floors & 25 classrooms running in Tin-shed at ground floor and have following shortcomings:-

1. First aid hose reel provided but not functional.
2. Automatic sprinkler system provided but not functional in basement.
3. Fire pumps provided but not functional at terrace.
4. Exit signage's are provided but not sufficient.
5. 25 Tin-shed/temporary class rooms are constructed along with boundary wall seems to be unsafe should be removed.
6. Basement with stage is being used as Multipurpose Hall instead of storage as per approved building plans.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
(With a request to take further action)
2. Executive Engineer, South West Zone-MCD-For information