



No. F6 /DFS/MS/School/NDZ/2023/381

Dated: 06/09/2023

To,
The Principal,
Kala Niketan International School,
Main Road Gazipur, Delhi-110096.

**Sub: -Reg. Fire Safety Certificate in r/o Kala Niketan International School, Main Road
Gazipur, Delhi-110096.**

Sir,

This has a reference to your Outdoor Diary no. 4104 dated - 25.07.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 03.08.2023 in the presence of Mrs. Shimla Rai (Principal) to see the compliance of Fire Safety Guidelines issued by this department vide letter no. F6/DFS/MS/School/NDZ/2020/06 dated 31.01.2020 and observed that building comprised of Basement + Ground + 03 upper floors only.

Following shortcomings were observed during time of inspection:

1. 02 Staircase of width 1.18 mtrs & 1.36 mtrs are provided against requirements of 1.50 mtrs each.
2. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/c @

Copy to: -

1. Dy. Director of Education, Block - D, Anand Vihar, Delhi -110092.