



118
75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 387

Dated: 11/09/2023

To

The Principal,
M.C Primary School,
Karampura G-Block,
New Delhi -110015.

Subject: Regarding issuance of Fire safety Certificate in respect of M/s. M.C. Primary School, G- Block, New Delhi – 110015.

Sir,

Please refer to your letter dated 28/07/2023 received through outdoor diary no. 4761 dated 10/08/2023 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officer concerned of this department on 25/08/2023 in presence of Smt. Roopvati (Principal) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/606 dated 23/09/2022.

However, the Status of the Shortcomings is as under.

S. no.	Shortcomings	Status
1.	First-Aid Hose Reels at each floor are provided but not functional.	Not Rectified
2.	Terrace fire pump of capacity 450 LPM capacity on terrace is provided but not functional.	Not Rectified

In view of above shortcomings the application for issuance of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Atul Garg)
Director

Copy To: -

1. The Directorate of Education, Old Secretariat, New Delhi.

o/c
31/8/2023