

C-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2023/SZ/ 380
To

Dated: 06/09/2023

The Principal,
Navjeevan Sarvodaya Kanya Vidyalaya Begumpur,
MMTC STC, Colony, New Delhi 110017

Sub: Regarding issuance of FSC in r/o Navjeevan Sarvodaya Kanya Vidyalaya Begumpur, MMTC
STC, Colony, New Delhi 110017.

Sir,

This has reference to your letter ref. no 639 dated 08/08/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.08.2023 in the presence of Mr. Bhim Singh (Estate manger) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but nonfunctional.
2. Terrace level Fire Pump capacity of 450 LPM x 2 provided but found nonfunctional.
3. Overhead tank found empty.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

O/m

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.