



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/BNQT/WZ/2023/ 203

Dated: 06/09/2023

To,

The Dy. Health Officer (West Zone),  
NDMC, Public health department,  
Karol Bagh Zone, Anand Parbat,  
New Delhi -110005.  
Email Id : - (dhowest zone@gmail.com).

Subject: **Regarding renewal of NOC from fire safety point of view in respect of M/s. S. and S. Hospitality Services INC Euphoria Mansion, located at Plot No. 16, Ground floor & First floor, Shivaji Marg, Main Najafgarh Road, New Delhi - 110015.**

Sir,

Please refer to your online application no. 2022083116911 dated 18/08/2023 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 30/08/2023 in the presence of Sh. Gautam (Manager) to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said Banquet Hall is running at Ground + First Floor & (Terrace floor room for Kitchen), in a building comprised of Ground + First Floor & (Terrace floor room for Kitchen). Fire safety arrangements such as fire extinguishers, first -aid hose reel, MOEFA, internal hydrant, pumping arrangements etc. have been provided in the building. However, the following shortcomings were observed.

1. Fire check door is found removed.
2. First Aid Hose reel is provided but not functional.
3. MOEFA is provided but not functional.
4. Internal hydrant is provided but not functional.
5. Terrace level pump capacity of 900lpm & 180lpm is provided but not functional.
6. Water storage tank capacity of 15000ltr is provided but found empty.
7. Exit Signages are not provided.

In view of above shortcomings the application for renewal of fire safety certificate is rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

(Atul Garg)  
Director

Copy To:-

1. The Owner/Occupier of M/s S. and S. Hospitality Services INC Euphoria Mansion, located at Plot No. 16, Ground floor & First floor, Shivaji Marg, Main Najafgarh Road, New Delhi - 110015.

8/9  
01/9/2023