



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023 | 386

Dated: 11/09/2023

To,

The Principal,
S.D Public School,
Kirti Nagar,
New Delhi- 110015.

Sub: - Inspection report in respect of S.D. Public School Located at Satguru Ram Singh Marg, Kirti Nagar, New Delhi-110015.

Sir,

This is in reference to your letter No. – SDPS/KN/3495/2023 dated 11/08/2023 on the subject cited above. In this connection, it is to inform you that the school building/premises was inspected by the officer concerned of this department on 25/08/2023 in presence of Ms. Dipti Malhotra (H.O.S), to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/640 dated 14/10/2022.

The Following Shortcomings Status is as under:-

S. no.	Shortcomings	Status
1.	First Aid Hose Reel is provided but not functional.	Not Rectified
2.	Internal Hydrant is provided but not functional.	Not Rectified
3.	Terrace fire pump of 450lpm provided but not functional & not on auto mode.	Not Rectified
4.	Overhead tank capacity of 2500ltr is found empty.	Not Rectified

In view of above shortcomings, the application for renewal Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
Director

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

o/c
31/8/2023