

C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2023/ 401

Dated: 12/09/2023

To

The Principal,
Arya Vedic Pathshala (Girls),
Gali No. 2, Multani Dhanda,
Pahar Ganj, New Delhi -110005.

Sub: Regarding issuance of FSC in r/o Arya Vedic Pathshala (Girls), Gali No. 2, Multani Dhanda, Pahar Ganj, New Delhi -110005.


Sir,

This has reference to your letter no. **nil** dated 10.08.2023 on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 31.08.2023 in the presence of **Principal** and following shortcomings were observed.

1. Alternate staircase to first floor is not provided.
2. Fire Extinguishers are not provided as per IS 2190.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Running school without valid Fire Safety Certificate is at the risk and liability of school management. Concerned authority may take action at their end.

Yours faithfully,



(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.

