

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HQS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI- 110001

No. F.6/DFS/MS/EH/2023/SZ/ 499

Dated: ...11/09/2023

To

The Dy. Health Officer, MCD,
Public Health Officer, Green Park Zone,
Aurobindo Marg, New Delhi 110016

Sub: Regarding renewal of FSC in r/o M/s BELLACIAO (A Unit of Innovation Hospitality) M-80,
Second floor, Greater Kailash Part-2, M Block Market, New Delhi 110048.

Sir,

This has reference with **MHA Portal ID 20230814144591 dated 14-08-2023** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 10.08.2023 in the presence of Mr. Veer to verify the fire safety measures installed in the building and observed that restaurant running at Second floor only of the building comprised of Basement, ground, plus three upper floors. During inspection, following points were observed:

1. First aid hose reel provided but found nonfunctional.
2. Automatic Sprinkler system provided but found nonfunctional
3. Terrace level pumps capacity 225 & 180 LPM fire fighting pumps are found removed.
4. Overhead tank capacity 5,000 ltrs found removed.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

at