

2/69

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2023/ 509

Dated: 12/09/2023

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

**Subject: Regarding renewal of NOC from fire safety point of view in respect of M/s  
Connaught Plaza Restaurant Pvt. Ltd. McDonalds Family Restaurant, Located  
at M2K Mutliplex, Ground and First Floor, Community Centre, Road No. 44,  
Pitampura, New Delhi - 110034.**

Sir,

Please refer to your online application no. 2023082315041 dated 23/08/2023 on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by the officer concerned of this department on 01/09/2023 in the presence of Sh. Tarikh to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor & First Floor in a building comprised of B1 + B2 + Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Internal Hydrant etc provided. However the following shortcomings were observed.

1. Alternate staircase is found closed.
2. Alternate exit door is found closed in ground & 1<sup>st</sup> floor.
3. Basement floor is also using as McDonald's store. It should be segregated with fire check door.

In view of above Shortcomings, the application for renewal of fire safety certificate is rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

  
(Atul Garg)  
Director

8/6/19 06/9/2023

Copy to: -

1. The Owner/Occupier, M/s Connaught Plaza Restaurant Pvt. Ltd. McDonalds Family Restaurant, Located at M2K Mutliplex, Ground and First Floor, Community Centre, Road No. 44, Pitampura, New Delhi - 110034.
2. The DHO, MCD, Keshav Puram Zone, Public Health Department, A- Block, Keshav Puram, New Delhi.