

2/09

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/ 389

Dated: 11 / 09 / 2023

To,

The Principal,  
M.C. Primary School,  
Kirti Nagar Ind. Area,  
New Delhi-110015.

**Sub: - Regarding Issuance of Fire Safety Certificate in r/o M.C Primary School, located at Kirti Nagar Ind. Area, New Delhi-110015.**

Sir,

Please refer to your letter dated 17/08/2023 received through outdoor diary no. 5241 dated 21/08/2023, on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 28/08/2023 in presence of Smt. Sushila Devi (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said School is running in ground plus two upper floors, in a building comprised of Ground Plus two upper floors. However, the following Shortcomings were observed.

1. 01 Staircase is provided having width 1.20 m. If one staircase is less then 1.5m then alternate staircase is not less than 0.75m.
2. First Aid Hose reels are provided but not functional.
3. Terrace fire pump of 450 lpm is provided but not functional.


In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

  
06/9/2023