



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 395

Dated: 12/09/2023

To

The Principal
M.C.Primary Co-ed School,
Dheerpur (CLZ), Delhi-110009.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary Co-ed School, (School I.D No- 1253095) located at Dheerpur (CLZ), Delhi-110009.

Sir,

Please refer to your letter No- Nil dated 25.08.2023 received in this department vide outdoor dairy No-5436 dated 25.08.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 01.09.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Sh. Lalit (Security Guard) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. 02 no's of staircases provided width of 1.20m each against the requirements of 1.50m each.
2. Fire extinguisher not provided.
3. Hose reel hose provided but not functional and damaged condition.
4. Terrace level fire pump capacity of 450lpm not provided.
5. Terrace level fire water tank capacity of 10,000ltr not provided.
6. Exit signage and floors signage not provided at strategic locations in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

Handwritten initials and signature