

C-21 DFA

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2023/ 393
To,

Dated: 12/09/2023

The Principal,
Naveen Public School,
Village Nithari,
Delhi-110086.

Sub: Issue of FSC in r/o Naveen Public School, Village Nithari, Delhi-110086.

Sir,

Kindly reference to online e-mail dated 13.07.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 07.08.2023, in presence of **Mrs. Sunita (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Grill gate found in one staircase.
2. First Aid hose reel not functional.
3. 15nos. fire extinguishers of ABC/Co2 type provided but found empty.
4. Terrace Fire pump with capacity 450 LPM provided but not functional.
5. 10,000 ltrs Over Head water captive tank provided but found empty & leak.
6. Exit signage not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000
O/e
Raj