

C-16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2023/SZ/ 397

Dated: 12/09/2023

To,

The Manager,
New Vishal Public School, C-27,
Vikas Nagar, Hastal, Uttam Nagar, New Delhi-110059.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o New Vishal Public School, C-27, Vikas Nagar, Hastal, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter NVPS/AUG-1/FIRE/2023 dated 14/08/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 29/08/2023 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Smt. Shashi Bala (Principal) was present and it was observed that the building is comprised of ground floor plus one upper floor and have following shortcomings:-

1. Both staircase blocked by furniture.
2. First Extinguishers are provided but not functional.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

o/c

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
(With a request to take further action)