

c/9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/SZ/2023/ EH/511

**NEW DELHI**

Dated: 12/09/2023

To,

The Addl. Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi.

**Subject: Issuance of NOC from fire safety point of view in r/o M/S Sama Foods Located at Shop No. 101 to 109, Pankaj Arcade – MLU, 1<sup>st</sup> floor, Plot No. 16, Sector – 10, Dwarka, New Delhi.**

Sir,

Please refer to online application No. 2023080213849, dated 28/08/2023 & 2023082815314 dated 29/08/2023 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned of this department on 05/09/2023 in the presence of Sh. Suresh (Manager) for fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Only one staircase of 1.17m width is provided against required two stairs of 1.5m.
2. Only one exit of 90 cm width is provided against required two exits of 1.5m.
3. Smoke exhaust system <sup>found</sup> not provided.
4. MOEFA found nonfunctional.
5. Terrace pump of 450 LPM found not provided.
6. Hydrant & Hose Reels are not provided.
7. Terrace fire water tank of 20,000 ltrs not provided.
8. Exit signage not provided.

Applicant may be requested to comply the shortcomings under intimation to this department for further consideration in the matter

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Manager, M/S Sama Foods Located at Shop No. 101 to 109, Pankaj Arcade – MLU, 1<sup>st</sup> floor, Plot No. 16, Sector – 10, Dwarka, New Delhi.
2. The Deputy Health Officer, Health Department, SDMC, Dhansa stand, Najafgarh, New Delhi – 110043.