

G-4

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Hospital/SZ/2023/1985

Dated: 14/09/2023

To

Mrs. Sarika Kwatra (Zonal Head),
Apollo Spectra Hospitals,
Plot No- 03, Block No- 34, Pusa Road,
WEA, Karol Bagh, New Delhi- 110005.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Apollo Spectra Hospitals, Plot No- 03, Block No- 34, Pusa Road, WEA, Karol Bagh, New Delhi- 110005 from fire safety and escape point of view.

Sir,

This has reference to your letter No. Nil, dated 25.08.2023, on the subject cited above. In this regard, it is to inform you that the aforesaid hospital building has been inspected by the officer concerned of this department on 12.09.2023 in presence of Sh. Ankit Sharma, to check the fire safety and means of escape arrangements as per guidelines issued by this department vide letter No. F.6/DFS/MS/BP/2022/724 dated 31.03.2022.

During the course of inspection following shortcomings were observed: -

1. Fire Check Doors found not provided in basement.
2. Sealing of electrical shaft not done.
3. Ventilation & pressurization system found not provided.
4. Safety cover of sprinkler head & detectors found not removed.
5. Fire pumps are not on auto mode.
6. Underground water storage tank capacity of 1,50,000 lts found vacant.
7. Exit Signage found not provided.
8. Special fire protection system found not provided for protection of electric installation.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further necessary action in the matter.

Yours faithfully,


(Anil Garg)
Director

Delhi Fire Service

Copy to: -

1. The Executive Engineer (Bldg.), NDMC, Civic Center, 8th floor, Mintoo Road, New Delhi.