

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2023/ 155

Dated: 06/07 /2023

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o B-99, Wazirpur Industrial Area, New Delhi.

Sir,

Please refer your online request ID No.- 10116282 dated 27/06/2023, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at B-99, Wazirpur Industrial Area, New Delhi.

Following shortcomings are observed:

1. The main staircase is not opening into Mezz. Floor.
2. The alternate exit of Mezz. Floor is not continuous to terrace level.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director

011-23414000

W C S