

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/ 1972

DATED: 13/09/2023

To,

The President / Secretary
M/S Chanakya CGHS Ltd.
Plot No-23, Sector-04, Dwarka,
New Delhi-110078.

Subject: - Renewal of Fire Safety Certificate in r/o M/S Chanakya CGHS Ltd. Located at Plot No-23, Sector-04, Dwarka, New Delhi-110078.

Sir,

Please refer to your letter No nil dated-18/08/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 01/09/2023 in the presence of Sh. Balbir Singh (President) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Staircases must be kept free from any obstruction & must not be locked at terrace.
3. Exit signage's found removed at some places.
4. Hoses and branches are found missing at some places. All hoses, branches & hose fittings must be ISI marked.
5. P.A. System found nonfunctional.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.