

C-10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2023/ 399

Dated:-12/.09/2023

To,

The Incharge,  
M/S M.C. Primary School,  
Jhandewalan Ward No. 92(KBZ),  
New Delhi -1100055.

**Sub: Regarding issuance of FSC in r/o M.C. Primary School, Jhandewalan Ward No. 92(KBZ),  
New Delhi -1100055.**

Sir,

This has reference to your letter no. nil dated 11.08.2023, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 31.08.2023 in the presence of **Incharge** and following shortcomings were observed.

1. Hose reel found non functional.
2. The pump found non functional.
3. Overhead fire water tank of 10,000 liter capacity is not provided.
4. Exit Signage not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Running school without valid Fire Safety Certificate is at the risk and liability of school management. Concerned authority may take action at their end.

Yours faithfully,

  
(Atul Garg)  
**DIRECTOR**

Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.

