



cl

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/EH/2023/SZ/ 521

Dated: 14/09/2023

To,

The DY. Commissioner of police
(Licensing) licensing branch 1st floor
Defence colony P.S NEW DELHI

Subject: Inspection report of M/s MIC Drop (A Unit of Chop House Hospitality Pvt. Ltd.), at M4, 2nd Floor, South Extension Part-2, New Delhi, from Fire Safety and means of escape point of view.

Sir,

Please refer to your letter received through Email-Nil dated 08.08.2023 on the subject cited above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 23.08.2023 in presence of Sh. Victor Murphy (General Manager) and observed that building comprised of Basement, Stilt, Ground & 2 upper floors.

Following shortcomings were found during the inspection:-

1. Manual Operated Electrical Fire Alarm (MOEFA) system found removed/damage.
2. Fire pumps were not in auto mode.
3. Exit Signage and floor marking is not provided in the building.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. Deputy Health Officer, Central Zone (MCD), Shiv Mandir Marg, Lajpat Nagar, New Delhi.
2. M/s MIC Drop (A Unit of Chop House Hospitality Pvt. Ltd.), at M4, 2nd Floor, South Extension Part-2, New Delhi.