

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/Parking/SZ/2023/ 1970

Dated: 12/09/2023

To

Col. M. P. Varghese (Dy. Director Amin.),  
Sir Ganga Ram Hospital, Rajinder Nagar,  
New Delhi- 110060.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Multi Level Car Parking at Sir Ganga Ram Hospital, Rajendra Nagar, New Delhi-60, from fire safety and escape point of view.

Sir,

This has reference to your letter No. SRGH/SEC/FIRE/MLCP/NOC/1006/2023, dated 18.08.2023, on above cited subject. In this regard, it is to inform you that the aforesaid Multi Level Car Parking has been inspected by the officer concerned of this department on 06.09.2023 in presence of Sh. Shiv Partap Singh (Fire Safety Officer) to check the fire safety and means of escape arrangements as per guidelines issued by this department vide letter No. F.6/DFS/MS/BP/2016/133 dated 16.06.2016.

During the course of inspection following shortcomings were observed: -

1. Different workshops/stores are provided in basement floor without any compartmentation.
2. The staircase leading to basement floor is found blocked due to store.
3. Wooden wastage has been stored in pump house.
4. At 10<sup>th</sup> floor beds, tables and other furniture's items has been found stored.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be renewal at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further necessary action in the matter.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Bldg.), NDMC, Civic Center, 8th floor, Mintoo Road, New Delhi.

GIC  
L