

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/ WZ/2023/ 1971

Dated: 13/09/2023

To,
Mr. Umesh Batra (Administrator),
Office of The Administrator-Cum-Returning Officer,
New Saraswati CGHS Ltd. Plot No.26/1, Sector-9, Rohini,
Delhi-110085.

Sub: Checking & Rectification of Fire Fighting System of r/o New Saraswati CGHS Ltd. Plot No.26/1, Sector-9, Rohini, Delhi-110085.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 11293 dated 14.02.2023 on the subject cited above The premise was inspected by the concern nominated authority of this department on 29.08.2023 in presence of Sh. Banwari Lal Sharma to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. An overhead water storage tank capacity of 10,000 ltr provided in each blocks but found leakage & empty.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings and FSC issued vide letter No.F.6/DFS/MS/2019/WZ/1321 dated 20.06.2019 will remain suspended till such time. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000