

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 490
To

Dated: 15.09.2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Hotel Olive at A-406, Block-A, Road No -4, Street No 8, Mahipalpur Extn, New Delhi -37

Sir,

This has reference with MHA Portal ID 2023082415149 dated 25-08-2023 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 13.09.2023 in the presence of Mr. Laxman of the Guest House. During the inspection, it was observed that the Guest House is running Basement, Ground plus Three Upper Floors. The shortcomings observed are as below:

1. First Aid hose reel provided but found nonfunctional.
2. Overhead tank capacity 2000 ltrs provided against the required capacity 5,000 ltrs.
3. The Occupancy above 3rd floor not acceptable as per clause 7.31 in UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. M/s Hotel Olive at A-406, Block-A, Road No -4, Street No 8, Mahipalpur Extn, New Delhi