



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 405

Dated: 18/09/2023

To

The Principal
Pioneer Public School,
A-1 Block, Sant Nagar, Delhi-84.

Sub: - Regarding renewal of fire safety certificate in r/o Pioneer Public School located at Gali No-26, Block A1, Sant Nagar, Burari, Delhi-110084.

Sir,

Please refer to your letter no. Nil received in this department vide outdoor dairy no.5683 dated: 04.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 12.09.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Mrs. Neelam (Attendant) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose provided but not functional and badly damaged condition some nozzles are missing.
2. Terrace level fire pump capacity of 450lpm found removed.
3. Terrace level fire water tank capacity of 5000ltr provided against the requirement of 10,000ltr.
4. Exit signage and floor signage found removed at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

60
13/9