



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

75
 आजादी का
 अमृत महोत्सव

No: F.6/DFS/MS/School/2023/WZ/ 406

Dated: 18/09/2023

To,

The Principal,
 Swastik Public School,
 Kh. No. 44, Sushan Vihar, Main Road,
 Ibrahimpur, Delhi-110036.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Swastik Public School, Kh. No. 44, Sushan Vihar, Main Road, Ibrahimpur, Delhi-110036.

Sir,

This has reference to your email id dated 22/08/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 22.08.2023 to see the compliance of the requisite fire safety measures. Sh. Anuj Kumar was present at the time of inspection.

During the course of inspection it was observed that previously this department had issued FSC for Ground and first floor in a building comprised of Ground and two upper floors vide letter no. F6/DFS/MS/School/2020/WZ/265 dated 06/08/2020 but now the school is found running on Ground plus two upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. Width of staircase found 1.35 m & 1.20 m against the required width of 1.5 m each.
2. There is only one continuous staircase up to terrace against the requirement of 2 continuous staircases up to terrace.
3. Door width at second floor found 1 m against the required width of 1.20 m.
4. Fire Extinguishers provided but found not functional.
5. First Aid Hose Reel provided but found not functional.
6. Terrace level pump of 450 lpm capacity not provided.
7. Overhead tank of 2500 ltrs capacity provided against the required capacity of 10,000 ltrs.
8. Exit signage's found not provided.
9. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

013/19

SKR

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.