

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2023/SZ/ 484
To

Dated: 18/09/2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s DEVRANA located at L 354A, Mahipalpur Extn., New Delhi 110037

Sir,

This has reference with MHA Portal ID 2023081714709 dated 19-08-2023 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 13.09.2023 in the presence of Mr. Naresh Kumar Jain of the Guest House. During the inspection, it was observed that the Guest House is running Basement, Ground plus Four Upper Floors. The shortcomings observed are as below:

1. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
2. The occupancy above 3rd floor not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

0/11 m