

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2023/NDZ/2023/ 2045

Dated:- 21/09/2023

To

The Manager,
M/S Alliance International Pvt. Ltd., 2E/21,
Jhandewalan Extension, Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Alliance International Pvt. Ltd., 2E/21, Jhandewalan Extension, Pahar Ganj, New Delhi.

Sir,

This has reference to letter no. nil dated 22/08/2023, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned department on 11/09/2023 in the presence of **Manager** and following shortcomings were observed: -

1. Fire check door found removed from the staircase serving to basement for compartmentation.
2. Hose reel found nonfunctional and nozzle found missing.
3. Alternate staircase was not available for the occupants available at other part of the building as the office was locked.
4. Sprinklers are not provided in basement.
5. Smoke management system in basement is not provided.

In view of above, Fire Safety Certificate (FSC) cannot be renewed. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit

Yours faithfully


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.