

C-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2023/SZ/ 485

Dated: 18/09/2023

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Delhi Aerocity Inn Guest House,
Situatd- L-22/379, NH-8, Mahipalpur Extn., New Delhi 110037

Sir,

This has reference to with MHA Portal ID 2023083015415 dated 30/08/2023 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 13.09.2023 in the presence of Mr. Pramod Kumar and observed that building comprised of Basement, Ground + 04 upper floors and following shortcomings were observed during inspection :

1. Smoke management system not provided as per clause 7.31 of UBBL 2016.
2. Carbon monoxide detector not provided as per clause 7.31 of UBBL 2016.
3. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)

DIRECTOR
DELHI FIRE SERVICE