



No. F6 /DFS/MS/EH/SZ/2023/ 531

Dated: 19/09/2023

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: -Regarding grant of Fire Safety Certificate in r/o M/s Dominos Pizza (Jubilant Foodworks Limited) Situated at Shop No.11-D/34, GF, FF & SF, Lajpat Nagar-II, New Delhi.

Sir,

with reference to the Online application ID no. 2023082915391 dated 31.08.2023 on the subject cited above, it is informed that the said restaurant was inspected by officer concerned from this department on 13.08.2023 in the presence of Mr. Asif (Manager) and it was observed that the restaurant is running at Upper Ground, First & Second floor of the building which is comprised of Basement + Upper Ground + 2 upper floors. During the inspection following shortcomings were observed:

1. Main & Alternate staircase of width 1.50 meters must be provided.
2. 2 nos. of door (exit) width of 1.50 meters must be provided at each floor.
3. Smoke management system not provided.
4. Hose reel & internal hydrant found not provided.
5. Manuel Operated Electrical Fire Alarm (MOEFA) system not provided.
6. Fire pump having capacity 450 LPM & head 40 m not provided.
7. Overhead tank capacity 20,000 liters exclusively for fire fighting found not provided.
8. Exit signages not provided.
9. Electrical meter situated at entry gate must be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
14/9/23.