

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2023/SZ/college/155
To

Dated: 20.09.2023

The acting Registrar,
South Asian University,
Rajput Road, Maidangarhi,
New Delhi 110068.

Sub: Regarding issuance of FSC in r/o The Faculty of Law and Humanities Building at South Asian University Complex, Maidan Garhi, New Delhi

Sir,

This has reference to your letter SAU/9-127/2022/Vol-IV/69 dated 23/08/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 13.09.2023 in the presence of Sh. Yogesh Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Width of internal 06 mtr road is encroachment at some places.
2. Pressurization system not provided.
3. The exit door width is 1.45 mtr provided against the required width of 1.50 mtr.
4. First Aid Hose Reel not functional.
5. MOEFA not working.
6. Public Address system not provided.
7. Automatic sprinkler system not functional in basement.
8. Internal & yard hydrants not functional.
9. Fire fighting pumps are not on auto mode

The same observation has already been issued and communicated earlier by this department vide letter of even no 08 dated 21.02.2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Asstt. Architect MCD, Town Planning Department, E Block.- 21- Floor, Civic Centre
New Delhi.