

0/25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/ 421

Dated: 20/09/2023

To,

The Principal,  
Goodley Public School (Nursury),  
BD Block, Shalimar Bagh,  
New Delhi-110088

**Sub: - Regarding Renewal of Fire Safety Certificate in r/o Goodley Public School (Nursury),**  
**Located at BD Block, Shalimar Bagh, New Delhi-110088.**

Sir,

Please refer to your letter no. 5/GPS/9/2023/3487 dated 04/08/2023 received through outdoor dairy No. 4819 dated 11/08/2023 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 12/09/2023 in presence of Smt. Prem Singh (Care Taker) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at Ground + 02 upper floor in a building is comprised of Ground + 01 upper floor was issued FSC vide letter no. F6/DFS/MS/WZ/2020/276 dated 14/08/2020. Fire Safety arrangements such as Fire Extinguishers, First -Aid Hose reel, Terrace pump, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. Terrace level fire pump of 450 LPM is provided but not on auto mode.
2. Overhead water storage tank 5000ltr provided but found empty.
3. Second exit passing through Classrooms on 1<sup>st</sup> & 2<sup>nd</sup> floor. It should be separate or an alternate exit shall must be provided.

In view of above Shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

16/09  
15/9/2023