



C/37

7
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 41B

Dated: 20/09 /2023

To,

The Principal,
Govt. Girls Sr. Sec. School,
Kohat Enclave,
New Delhi-110034.

Sub: - Regarding issuance of fire safety certificate in r/o Govt. Girls Sr. Sec. School
Located at Kohat Enclave, New Delhi - 110034. (School Id - 1411259)

Sir,

Please refer to your Email dated 23/08/2023 on the subject cited above. In this connection, it is to inform you that the said building/premises were inspected by the officer concerned of this department on 04/09/2023 in presence of Sh. Rohit Yadav to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running Ground + 3 upper floors in a building comprised of Ground + 03 Upper Floors. Fire safety arrangements Such as Fire Extinguishers, First -Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. First Aid Hose Reels are provided but not functional.
2. Terrace level pump capacity of 450lpm is provided not functional.
3. Exit Signages is not provided.

In view of above Shortcomings, the application for issuance of fire safety certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Signature)
(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

(Signature)
14/9/2023