

c/109

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2023/CH/487

Dated: 20/09/2023

To,

The Manager,
M/S Saina International Guest House,
2324 & 2471, Chuna Mandi,
Pahar Ganj, New Delhi.

Sub: **Regarding issuance of FSC in r/o M/S Saina International Guest House at 2324 & 2471, Chuna Mandi, Pahar Ganj, New Delhi.**

Sir,

This has reference to online id no.2023090415625 dated 04/09/23, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned department on 12/09/2023 in the presence of **Manager** and following shortcomings were observed: -

1. Fire check doors not provided as per gazette notification 2019 .
2. Building plan is not uploaded on the portal as per existing profile of guest house.

In view of above, Fire Safety Certificate (FSC) cannot be renewed. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.