



2115

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/School/NDZ/2023/ 409

Dated: 20/09/2023

To,

The Principal
Saint Raman School,
A-Block, Gharauli Dairy,
Mayur Vihar, Phase-III, Delhi-110096.

Sub: - Regarding grant of Fire Safety Certificate in r/o Saint Raman School, located at A- Block, Gharauli Dairy, Mayur Vihar, Phase-III, Delhi-110096.

Sir,

This has a reference to your Outdoor Diary No. 5110 dated - 18.08.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 28/08/2023 in the presence of Mr. Raman Raj Khanna (Principal) and observed that building comprised of Ground floor + 03 upper floor.

Following shortcomings were observed during time of inspection:

1. Overhead tank capacity 2,000 liters provided against the requirement of 5,000 liters.
2. Exit Signage's not provided.
3. Hose reel hose provided but non functional.
4. Fire pump of 220 LPM provided but non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
etc @

Copy to: -

1. Director of Education, D - Block Anand Vihar, Delhi.