



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/NDZ/2023/ 413

Dated: 28/09/2023

To,

The Principal,
Sardar Patel Modern School,
Ghoroli Mayur Vihar-III, Delhi-110096..

Sub: -Reg. Fire Safety Certificate in r/o Sardar Patel Modern School, Ghoroli Mayur Vihar-III, Delhi-110096.

Sir,

This has a reference to your Outdoor Diary No. 5456 date 25.08.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 28/08/2023 in the presence of Mrs. Seli Bhandari (Principal) and observed that building comprised of Ground floor + 02 upper floor only.

Following shortcomings were observed during time of inspection:

1. Hose Reel provided but not functional.
2. Pump provided but not functional.
3. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/c @

Copy to: -

1. Dy. Director of Education, D- Block Anand Vihar, Delhi -110092.