



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/4
C/4

No: F.6/DFS/MS/School/2023/WZ/ 414

Dated: 20/09/2023

To,

The Principal,
SSK Play & Public School,
Kh. No. 37/2, Gali No. 10, Sanjay Colony,
Safiyabad Road, Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o SSK Play & Public School, Kh. No. 37/2, Gali No. 10, Sanjay Colony, Safiyabad Road, Narela, Delhi-110040.

Sir,

This has reference to your letter number nil dated 28/08/2023 received via outdoor diary number 5463 dated 28/08/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 12.09.2023 to see the compliance of the requisite fire safety measures. Sh. Sunil was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and three upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. There is only one staircase having width 1.10 m provided against the requirement of 2 staircases of width 1.5 m each and both the staircases should reach up to terrace.
2. Fire Extinguishers not provided as per the requirement of 1@300 sqm.
3. First Aid Hose Reel found not provided.
4. Terrace level pump of 450 lpm capacity not provided.
5. Overhead tank of 10,000 ltrs found not provided.
6. Exit signage's found not provided.
7. Building plans on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully


(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.