



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
जाज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/NDZ/2023/ 415

Dated: 20/09/2023

To,
The Manager,
Stepping Stone Convent School,
Acharya Niketan, Delhi-110091.

Sub: - Reg. Fire Safety Certificate in r/o Stepping Stone Convent School located at, Acharya Niketan, Delhi-110091.

Sir,

This has a reference to your Outdoor Diary No. 5112 date 18.08.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 28/08/2023 in the presence of Mrs. Anu Kapoor (Manager) and observed that building comprised of Ground + 03 Upper floors but School Running at Ground + 02 upper floors only.

Following shortcomings were observed during time of inspection:

1. Fire Extinguisher provided but not functional.
2. Pump provided but not functional.
3. Exit Signage's not provided.
4. Overhead tank of 5,000 liters capacity is provided against the requirement of 2,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE
o/c @

Copy to: -

1. The Director of Education, GNCT of Secretariat, Delhi- 110054.