

chb

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2023/ 420
To,

Dated: 20/09/2023

The Principal,
S.V.T Public School,
B-650, Mittal Market,
Hind Vihar, Prem Nagar-III Kirari,
Delhi- 110086.

Sub: Issue of FSC in r/o S.V.T Public School, B-650, Mittal Market, Hind Vihar, Prem Nagar-III, Kirari, Delhi-110086.

Sir,

Kindly reference to online e-mail dated 21.07.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 07.08.2023, in presence of **Smt. Anita Sharma** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. First Aid hose reel not functional and hose reel nozzle missing at some place.
2. 08nos. fire extinguishers of ABC type provided but found empty.
3. Terrace Fire pump with capacity 450 LPM provided but not functional.
4. 1000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs
5. Exit signage not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

ae
Ag