

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/WZ/2023/2079

Dated: - 27/09/2023

To,

The Authorized Signatory,
D-113, Block-D,
Keshopur Industrial Area,
New Delhi-110018.

Subject: Regarding renewal of Fire Safety Certificate in respect of D-113, Block-D, Keshopur Industrial Area, New Delhi-110018.

Sir,

This has reference to your letter no. nil dated 28.08.2023 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officers concerned of this department from fire safety point of view on 21.09.2023 in the presence of Sh. Pawan Singh (Manager) to see compliance of the shortcomings communicated vide this department letter no. F6/DFS/MS/WZ/2023/1279 dated 20.06.2023.

During the course of inspection it has been observed that the Management has rectified some of the shortcomings, the status is as under:-

S. no.	Shortcomings	Status
1.	Fire Check Doors are not provided	Not Rectified
2.	Door Size 1.10 m provided against required of 1.5 m	Not Rectified
3.	Smoke Management System is not provided at basement floor	Not Rectified
4.	First aid hose reel hose found non-functional	Functional
5.	Terrace pump of 450 lpm found non-functional	Functional
6.	Fire service inlet is not provided	Provided
7.	Exit signages are not provided	Provided but inadequate
8.	Standby power supply is not provided	Not Rectified
9.	Lift well opening at all floors to be sealed by brick wall as lift car is not yet installed	Lift Car installation work is going on

In view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Atul Garg)
Director

25/9/23