

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/509  
To

Dated: 29.10.2023

The Addl. Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony  
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Hotel Daya Continental at A-6, Road No 1, Mahipalpur, Extension, New Delhi 110037

Sir,

This is in reference with MHA Portal ID 2023081014353 dated 12-09-2023 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 25/09/2023 in the presence of Mr. Mohan Singh of the Guest House. During the inspection, it was observed that the Guest House is running Ground plus Three Upper Floors. The shortcomings observed are as below:

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
3. First Aid hose provided but found nonfunctional.
4. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
5. Internal hydrant provided but found nonfunctional.
6. Terrace level fire fighting pump provided but found not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

21/10/23

Copy to:-

1. M/s Hotel Daya Continental at A-6, Road No 1, Mahipalpur, Extension, New Delhi 110037